



UNCP Compressed Gas Cylinders Checklist

- Are cylinders with a water weight capacity over 30 pounds equipped with means for connecting a valve protector device or with a collar or recess to protect the valve?
- Are cylinders legibly marked to clearly identify the gas contained?
- Are compressed gas cylinders stored in areas that are protected from external heat sources such as flame impingement, intense radiant heat, electric arcs or high temperature lines?
- Are cylinders located or stored in areas where they will not be damaged by passing or falling objects or subjected to tampering by unauthorized people?
- Are cylinders stored or transported in a manner to prevent them from creating a hazard by tipping, falling or rolling?
- Are cylinders containing liquefied fuel gas stored or transported in a position so that the safety relief device is always in direct contact with the vapor space in the cylinder?
- Are valve protectors always placed on cylinders when the cylinders are not in use or connected for use?
- Are all valves closed off before a cylinder is moved, when the cylinder is empty, and at the completion of each job?
- Are low pressure fuel gas cylinders checked periodically for corrosion, general distortion, cracks or any other defect that might indicate a weakness or render it unfit for service?
- Does the periodic check of low pressure fuel gas cylinders include a close inspection of the cylinders' bottoms?